



發電機組概況

機組編號	引擎型號	發電機型號	設置時間	最後停止運轉時數 (至2011/08/30)	上次大保養 運轉時數
DG1	WARTSILA	ABB HSG900XU10 11,400 Volt 7,875KVA 60 Hz PF:0.8 720 RPM	1996	55,503	53,222
DG2	18V32		1996	63,802	54,731
DG3	720 RPM		1998	51,293	43,150
DG4	6,300KW		1998	49,900	42,939
DG5	WARTSILA		2001	35,116	26,487
DG6			2001	36,547	26,963
DG7			2002	26,123	15,456
DG8			2002	26,225	14,036
DG9			2002	26,384	14,836
DG10			2002	11,173	6,000
DG11			2002	25,617	15,308
DG12			2002	24,450	14,958



汽電發電機 (照片實景一覽)

汽電主機房全景



汽電主機房全景



汽電輔機設備及管路



汽電輔機設備及管路